

CORRIGENDUM
(Authenticated copy of the corrigendum to be enclosed along with Part-I Technical bid)

Two Part E-Bid Open Tender for providing Ante Cold Room with PUF insulation and 5 Nos. of Hatch Door with strip curtain, Air curtain in SS 304 casing for hatch doors in the Ice Cream Loading Dock and 4 Nos. of Hatch Door with strip curtain, Air curtain in SS 304 casing for hatch doors in Fermented Loading Dock and 2 Nos. of Refrigeration Unit with +4 deg C room temperature with suitable indoor and outdoor units for Ice Cream Product Loading Dock and Fermented Product Loading Dock at Products Dairy

The following amendments are hereby made in the tender documents for providing Ante Cold Room with PUF insulation and 5 Nos. of Hatch Door with strip curtain, Air curtain in SS 304 casing for hatch doors in the Ice Cream Loading Dock and 4 Nos. of Hatch Door with strip curtain, Air curtain in SS 304 casing for hatch doors in Fermented Loading Dock and 2 Nos. of Refrigeration Unit with +4 deg C room temperature with suitable indoor and outdoor units for Ice Cream Product Loading Dock and Fermented Product Loading Dock at Products Dairy

Technical Bid

1. As per tender document, technical specification under the head of Technical Specifications of the proposed Ante Cold Room(25.8 x 2.7 x 3m) for Ice Cream Product Loading Dock (Page no.23 and 24, Sl. No.8,9,11,13,15, 16, 17, 24, 25 and 29) & under the head of Required Quantity (Page No.24, Sl. No.7 and 10) is as follows:

Sl. No.	Description	Parameters	Remarks
8.	Material of Insulation	RPUF	Make: Rinack, Orchid Enterprises, Meta flex
9.	Thickness of Insulation (mm)	80mm for the walls	Make: Rinack, Orchid Enterprises,

		& ceiling	Meta flex
11.	Wall	80MM PUF slab	Make: Rinack, Orchid Enterprises, Meta flex
13.	Thickness of insulation of door	80MM PUF slab	Make: Rinack, Orchid Enterprises, Meta flex
15.	Type of door	Manual Swing	Make: Rinack, Orchid Enterprises, Meta flex
16.	Size of Hatch Door	80mm x 1m x 1m, with	Make: Rinack, Orchid Enterprises, Meta flex
17.	Air Curtains	SS Casing, Industrial Type	Make: Almonard
24.	No. of Condensing Unit	2 No	Make: Copeland, Rinac
25.	No. of Evaporator Units	2 No	Make: Copeland, Rinac
29.	Type of Light Fitting	LED 40W	Make: Philips, Crompton

Required Quantity

Sl. No.	Description	Quantity	UOM
7.	Philips LED Light Fitting 4ft – 40W	20	NOS.
10.	Emerson make air cooled hermetic condensing unit with 4kw capacity and suitable for +4 deg C room temperature and suitable evaporator with SS casing which is Rinac Make.	2	NOS.

Technical specification under the head of Technical Specifications of the proposed Ante Cold Room(25.8 x 2.7 x 3m) for Ice Cream Product Loading Dock (Page no.23 and 24, Sl. No.8,9,11,13,15, 16, 17, 24, 25 and 29) & under the head of Required Quantity (Page No.24, Sl. No.7 and 10) may be read as follows:

Sl. No.	Description	Parameters	Remarks
Addition:			
8.	Material of Insulation	RPUF	Make: Rinac, Orchid Enterprises, Meta flex

9.	Thickness of Insulation (mm)	80mm for the walls & ceiling	Make: Rinac, Orchid Enterprises, Meta flex
11.	Wall	80MM PUF slab	Make: Rinac, Orchid Enterprises, Meta flex
13.	Thickness of insulation of door	80MM PUF slab	Make: Rinac, Orchid Enterprises, Meta flex
15.	Type of door	Manual Swing	Make: Rinac, Orchid Enterprises, Meta flex
16.	Size of Hatch Door (SS Frame)	80mm x 1m x 1m, with	Make: Rinac, Orchid Enterprises, Meta flex
17.	Air Curtains	SS Casing, Industrial Type	Make: Almonard/ Euronics/Russell/ Mitsubishi
24.	No. of Condensing Unit	2 No	Copeland/ Emerson/Rinac make
25.	No. of Evaporator Units	2 No	SS 304 casing Make: Guntner/ Rinac/ALFA LU-VE/ Star Coolers
29.	Type of Light Fitting	LED 40W	Make: Philips, Crompton Type: 2x2 TLED Waterproof with lamp

Required Quantity

Sl. No.	Description	Quantity	UOM
7.	Philips/Crompton LED Light Fitting 4ft – 40W Type: 2x2 TLED Waterproof with lamp	20	NOS.
10.	Emerson make air cooled hermetic condensing unit with 4kw capacity and suitable for +4 deg C room temperature and suitable evaporator with SS 304 casing which is Make: Guntner/ Rinac/Alfa Lu-Ve/Star Coolers	2	NOS.

2. As per tender document, technical specification under the head of Technical Specifications of the proposed Ante Cold Room(19.4 x 2.55 x 3.3m) for Fermented Product Loading Dock(Page no.25 & 26, Sl. No.8,9,11,13,15 and 16)

& under the head of Required Quantity (Page No.26, Sl. No.9 and 12) is as follows:

Sl. No.	Description	Parameters	Remarks
8.	Material of Insulation	RPUF	Make: Rinack, Orchid Enterprises, Meta flex
9.	Thickness of Insulation (mm)	80mm for the walls & ceiling	Make: Rinack, Orchid Enterprises, Meta flex
11.	Wall	80MM PUF slab	Make: Rinack, Orchid Enterprises, Meta flex
13.	Thickness of insulation of door	80MM PUF slab	Make: Rinack, Orchid Enterprises, Meta flex
15.	Type of door	Manual Swing	Make: Rinack, Orchid Enterprises, Meta flex
16.	Size of Hatch Door	80mm x 1m x 1m, with	Make: Rinack, Orchid Enterprises, Meta flex
17.	Air Curtains	SS Casing, Industrial Type	Make: Almonard
24.	No. of Condensing Unit	2 No	Make: Copeland, Rinac
25.	No. of Evaporator Units	2 No	Make: Copeland, Rinac
29.	Type of Light Fitting	LED 40W	Make: Philips, Crompton

Required Quantity

Sl. No.	Description	Quantity	UOM
9.	Philips LED Light Fitting 4ft	34	NOS.
12.	Copeland make hermetic condensing unit with 4kw capacity and suitable for +4 deg C room temperature and suitable evaporator with SS casing.	2	NOS.

Technical specification under the head of Technical Specifications of the proposed Ante Cold Room(19.4 x 2.55 x 3.3m) for Fermented Product Loading Dock(Page no.25 & 26, Sl. No.8,9,11,13,15 and 16) & under the head of Required

Quantity (Page No.26, Sl. No.9 and 12) may be read as follows:

Sl. No.	Description	Parameters	Remarks
Addition:			
8.	Material of Insulation	RPUF	Make: Rinac, Orchid Enterprises, Meta flex
9.	Thickness of Insulation (mm)	80mm for the walls & ceiling	Make: Rinac, Orchid Enterprises, Meta flex
11.	Wall	80MM PUF slab	Make: Rinac, Orchid Enterprises, Meta flex
13.	Thickness of insulation of door	80MM PUF slab	Make: Rinac, Orchid Enterprises, Meta flex
15.	Type of door	Manual Swing	Make: Rinac, Orchid Enterprises, Meta flex
16.	Size of Hatch Door (SS Frame)	80mm x 1m x 1m, with	Make: Rinac, Orchid Enterprises, Meta flex
17.	Air Curtains	SS Casing, Industrial Type	Make: Almonard/ Euronics/Russell/ Mitsubishi
24.	No. of Condensing Unit	2 No	Make: Copeland/ Emerson/Rinac
25.	No. of Evaporator Units	2 No	SS 304 casing Make: Guntner/ Rinac/Alfa Lu-Ve/Star Coolers
29.	Type of Light Fitting	LED 40W	Make: Philips, Crompton Type: 2x2 TLED Waterproof with lamp

Required Quantity

Sl. No.	Description	Quantity	UOM
9.	Philips/Crompton LED Light Fitting 4ft – 40W Type: 2x2 TLED Waterproof with lamp	34	NOS.
12.	Copeland make hermetic condensing unit with 4kw capacity and suitable for +4 deg C room temperature and suitable evaporator with SS 304 casing which is Make: Guntner/ Rinac/Alfa	2	NOS.

	Lu-Ve/Star Coolers		
--	---------------------------	--	--

3. As per tender document, Check List(Page no.38, Sl. No.6) of technical bid is as follows:

CHECK LIST

S. No.	Description	Bidders Response
6.	Whether documentary evidence for average annual sales turn-over for the last three financial years (2020-21, 2021-22 & 2022-23) are uploaded as per tender clause 3.9 are uploaded	Yes/No

Check List(Page no.38, Sl. No.6) of technical bid may be read as follows:

CHECK LIST

S. No.	Description	Bidders Response
6.	Whether documentary evidence for average annual sales turn-over for the last three financial years (2021-22, 2022-23 & 2023-24) are uploaded as per tender clause 3.9 are uploaded	Yes/No

Joint Managing Director.