

CORRIGENDUM
(Authenticated copy of the corrigendum to be enclosed along with Part-I Technical bid)

Two Part E-Bid Open Tender for the renovation of Effluent Treatment Plant(ETP) and for Operation and Maintenance of ETP for 3 years At Ambattur Dairy

The following amendments are hereby made in the tender documents for the renovation of Effluent Treatment Plant(ETP) and for Operation and Maintenance of ETP for 3 years At Ambattur Dairy:

Technical Bid

1. As per tender document, the Technical Specification(Page no.23, Sl. No.1) of technical bid is as follows:

S. No.	Name of the Equipment	Work Description	Qty.	Size	Volume in Litres	Specification
1.	Equalization tank	Cleaning of scum	1 Lot	15m x 3m x 4m(H)	1,50,000	Scum to be removed for 15m x 3m x 0.06m(H)
		Providing sufficient coarse bubble air diffusers for equalization tank and 4 Nos. of collection walls	1 Lot			6" Dia. B Class GI Pipe: 12 mtrs. Length, 3" Dia. B Class GI Pipe: 24 mtrs. Length, 1/2" Dia. SS 304 Grade pipe of thickness 1.65mm: 120 mtrs. Length and fabricating with suitable flanges, bend, valves, etc. Providing 17 Nos. of coarse bubble diffusers of length 2 mtrs. each for equalization tank and grid well III. Then providing coarse bubble diffusers of length 1.5 mtrs. each of quantity 10 Nos. for gridwell I, II and collection well. Preferred Make for Coarse Bubble Diffusers: Rehau/ OTT Magnum/ EDI/ Cogen/ Envicon /Aquaflux. Membrane Tube Diffuser Length 2200mm and 1700mm is buoyancy free. MOC of the support pipe is Polypropylene(PP). MOC of the membrane is Silicone, Length both sides 1000mm and 750mm each side.

Technical Specification(Page no.23, Sl. No.1) of technical bid may be read as follows:

S. No.	Name of the Equipment	Work Description	Qty.	Size	Volume in Litres	Specification
1.	Equalization tank	Cleaning of scum	1 Lot	15m x 3m x 4m(H)	1,50,000	Scum to be removed for 15m x 3m x 0.06m(H)
		Providing sufficient coarse bubble air diffusers for equalization tank and 4 Nos. of collection wells	1 Lot			6" Dia. B Class GI Pipe: 12 mtrs. Length, 3" Dia. B Class GI Pipe: 24 mtrs. Length, ½" Dia. SS 304 Grade pipe of thickness 1.65mm: 120 mtrs. Length and fabricating with suitable flanges, bend, valves, etc. Providing 17 Nos. of coarse bubble diffusers of length 2 mtrs. each for equalization tank and grid well III. Then providing coarse bubble diffusers of length 1.5 mtrs. each of quantity 10 Nos. for gridwell I, II and collection well. Preferred Make for Coarse Bubble Diffusers: Rehau/ OTT Magnum/ EDI/ Cogen/ Envicon /Aquaflux. Membrane Tube Diffuser Length 2200mm and 1700mm is buyoancy free. MOC of the support pipe is Polypropylene(PP). MOC of the membrane is Silicone, Length both sides 1000mm and 750mm each side.

Joint Managing Director.